

Flame Certificate

Woven Together

031802

AiNO

Woven Together (ground) was tested and met the following flammability requirements:

FLAMMABILITY:

ASTM-E84 Tunnel Test, Class A

CAN/ULC-S102.2 Passed all requirements

Meets or exceeds requirements for flame spread, smoke development and flashover

Contact info@hivecreative.com with any questions.